



NOTE

1. MANHOLE BASES FOR MAINS 18" AND LARGER SHALL BE COATED PER SM-07
2. LOWEST POINT ON SHELF SHALL BE EVEN WITH TOP OF PIPE.
3. CAST IN PLACE MANHOLE BASES CAST WITH 660-CW-4000 CONCRETE (WITHOUT CALCIUM CHLORIDE CC) OR WITH 560-C-3250 TREATED WITH A MINIMUM OF 2% CC SOLUTION IN ACCORDANCE WITH 201-1 MAY HAVE MANHOLE SHAFT AND CONE TO A MAXIMUM HEIGHT OF 25' STACKED AFTER 24 HOURS OF CURE. SHORTER CURING TIMES, DEEPER INSTALLATIONS, AND ALTERNATE CONCRETE MIX DESIGNS REQUIRE ENGINEER'S PRIOR APPROVAL.

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE	
ORIGINAL	KA	A. OSKQUI	0910			
				<b>SEWER MANHOLE BASE</b>	COORDINATOR	R.C.E. 65271 DATE
					DRAWING	<b>SDS-120</b>
					NUMBER	